



Operating & Maintenance

Orca doors: Intego

General specification

Orca door leaves are constructed from 44mm and 54mm high performance solid particleboard core. Door leaves are covered with a 2mm PVC having either a textured or smooth surface finish, and with radius vertical edges.

The doors are supplied with a solid casing frame, finished in a lacquer containing an antibacterial agent, or with a protective PVC wrapping, and with the frame having an integral stop. The doors are hung on 3 number hinges where required.

Fire resistance

Tested to BS 476: Part 22 1987 by Chiltern International Fire Ltd.

Orca doors can be offered as a door or doorset, and can be supplied non-rated, or with a FD30 or FD60 rating.

Over panels

Over panels and side panels can be accommodated with the doorset. These will be detailed and assessed during the quotation of a door set to ensure the correct configuration is adopted to meet the criteria for fire rating.

Lippings

All Orca Intego doors will be supplied with hardwood lippings, concealed with either a square or radius vertical edge. Doors will normally be supplied with lippings to both vertical and horizontal edges, both covered with 2mm PVC.

Door frames

Softwood or Hardwood: 70mm x 32mm section. Minimum density 450 kgs/m³. MDF 70mm x 30mm section
Minimum density 700 kg

Softwood frame are not permitted for 60 minute doors.

Orca door frames are supplied unfinished, with a primer coating, a 40% sheen antibacterial lacquer, or PVC encapsulation.

Intumescent & smoke seals

All necessary fire and smoke seals are included.

All factory fitted hinges, locks/latches, strike plates and floor spring accessories will be protected with Intumescent gaskets. Any ironmongery not factory fitted will require protecting with intumescent gaskets. For further advice please provide full specification of components.

Orca Building Products
Limber Road
Kirmington
DN39 6YP

0844 8476702

Glazing

Orca door sets are factory glazed, when specified, using clear laminated fire resisting glass in conjunction with intumescent materials. The glass is retained using a purpose-made, pin-fixed, hardwood splayed and rebated or square section glazing bead.

The maximum permitted glazed area per leaf must not exceed 1.75m² throughout the configuration range.

Apertures shape is unrestricted and may be in multiple or single paned form providing glazing is not less than 100mm from the door leaf edges, not less than 100mm from any door edge and not less than 80mm between apertures.

The Orca range of standard vision panel sizes and configurations have a reduced lead time.

Ironmongery

An extensive range of ironmongery is permitted for use with Orca fire doors. Contact Orca Doors for details.

Decorative Finishes

Orca Intego doors are finished in a 2mm PVC with either a smooth or textured finish.

Size Adjustment

Door sets are manufactured to suit specific opening sizes and door leaves and any adjustment of door set sizes during installation may invalidate the fire rating status of the door set.

Storage

Orca door sets should be stored within a carefully controlled environment similar in temperature and humidity to that intended for final use.

Installation

See the Orca Doors installation instructions leaflet.

Installation instructions should be carefully adhered to in order that fire resistance is maintained.

Orca Doors can offer a fully certified fire door installation service if necessary.

Environment

Orca door sets can be supplied with FSC chain of custody

COSHH

In normal, proper use the product does not present any risks. However any attempt to machine or abrade the components in any way is likely to produce wood dust and risk assessments should be carried out. Furthermore, such modifications may invalidate the fire rating status of the door set and advice should be sought from Orca Doors.

The storage, installations and aftercare instructions issued by Orca Doors should be followed at all times. Specifiers and designers should refer to Approved Document M of the Building Regulations in order to ensure that features specified for the door sets will comply with the requirements of current legislation relating to access, especially for disabled persons.

MSDS

Material safety data sheets for materials used in the production of Orca door sets are available on request



012

Certificate Number
643

Date of initial registration
22 November 2012

Date of last issue
22 November 2012

Date of expiry
21 November 2015

REGISTRATION CERTIFICATE



The use of the accreditation mark indicates accreditation in respect of those activities covered by the accreditation certification 012



This is to certify

Orca Building Products T/A Orca Doors

Limber Road
Kirmington
North Lincolnshire
DN39 6YP

Meets the requirements of
The BM TRADA Scheme for
Fire Doors and Doorsets to
BS 476 part 22 or BS EN 1634-1

Signed on behalf of BM TRADA Certification Ltd
Vic Bowen, Chief Operating Officer

Chiltern House, Stocking Lane, High Wycombe, Buckinghamshire, HP14 4ND

Further clarification regarding the scope of this certificate and verification of the certificate is available through BM TRADA at the above address or at www.bmtrada.com

This certificate remains the property of BM TRADA Certification Ltd. To whom it must be returned on request.

Orca Building Products
Limber Road
Kirmington
DN39 6YP

0844 8476702



Fire Door Maintenance

Fire doors are intended to facilitate a similar level of fire resistance as per the structural elements of a building. However, since doors are often opened and closed many times a day, it is important therefore for regular inspection be performed.

Fire doors should therefore be examined at six-monthly intervals as follows;

- Recommended clearance of 3 mm (between door and frame) along head, down sides
- Where applicable, any signs of damage, to glass or glazing system as the glass and glazing system are critical to the performance of the fire door.
- Fire and smoke seals (as maybe fitted) for any signs of damage, degradation or missing in part or total, as either of these will have serious implications on the fire door performance
- Hinges should be inspected for signs of wear. Worn hinges should be replaced with those that perform in accordance with the latest edition of BS EN 1935
- Ensure that (where fitted) the latch or lock furniture moves freely and engages fully. Damaged or badly worn latch or lock furniture should be replaced immediately
- Self-closing devices should be examined to ensure it closes the door leaf properly. The door should close effectively from any angle. There are a number of reasons why doors may fail to close
 - Check that there are no foreign bodies or other objects obstructing the door.
 - Check that any smoke seals (as maybe fitted) remain correctly fitted and are undamaged.
 - Check the latch (if fitted) to ensure correct operation

Any self-closing device (as maybe fitted) which is unable to be effectively adjusted should be replaced using a closer that has been validated by test for use on a door assembly of similar specification, and performs in accordance with the latest edition of BS EN 1154

It is not easy to repair doors and maintain the interactive behaviour of the various component parts, and except for minor repairs to 30 minute fire rating door leaf which Orca Doors recommend are performed via a professional source, where significant damage is detected the door leaf should be replaced in total. Door leaves providing a 60 minute fire rating or higher should be replaced, not repaired

Note: In the event of damage that necessitates the replacement of one leaf of a double door, both leaves should be replaced with a new matching pair. As a commitment of continuous improvement and possible changes of legislative requirement, would make it virtually impossible to ensure that a replacement single leaf would be of identical construction to that being removed.



Fire Door Decoration

Fire door leaves are generally not required to provide a specific surface spread-of-flame barrier, and may therefore be re-decorated as desired.

Whilst suggested that the over painting/varnishing intumescent seals does not have detrimental effects, it is recommended that such action is limited to a maximum of 5 (five) coatings

PLEASE NOTE THAT ORCA INTEGO DOORS ARE PRODUCED WITH A NON PORUS PVC THAT CAN NOT BE PAINTED.

Where intumescent seals are incorporated within the doorframe the use of heat or chemicals in preparation for re-coating should be avoided

Certified fire doors supplied by Orca Doors are permanently marked with their declared fire resistance period by means of a colour-coded plug(s). It is therefore recommended to avoid painting over the plug(s) during re-decoration

Cleaning

Orca 2mm PVC is designed to absorb impact, and is solid colour throughout the material.

General

The surfaces of Orca PVC panels can be easily cleaned with a dry or damp cloth and, if necessary, a mild household cleaner. Wipe damp surfaces with an absorbent cloth. Use of concentrated acid, caustic or abrasive cleaning agents is not recommended.

Remove severe soiling

Severely dirty surfaces or areas where normal soiling* has built up over a long period of time are easy to clean with hot water and an interior detergent- or soap-based cleaning agent, applied with a damp sponge or soft nylon brush. Wipe off with a clean damp cloth and remove any excess liquid immediately.

** dust, pencil, ball pen, ink, coffee, tea, fruit juice, lipstick, grease, nicotine stains, shoe polish, urine, soap residues, limescale, water-soluble paints and adhesives*

Frequent cleaning

The recommended method for everyday cleaning of Orca PVC is warm water with a mild universal cleaning agent applied with a sponge or soft nylon brush. This is the ideal way to remove most light, recent soiling. Wipe damp surfaces with an absorbent cloth. Use of concentrated acid, caustic or abrasive cleaning agents is not recommended.

Orca warranties do not apply in case of improper or incorrectly performed cleaning. For the use of any cleaning agent, please consider (national) safety and environmental regulations

DECOSHEET PVC paneling has been tested for its resistance to the main types of cleaning materials, disinfectants and antiseptic products used by public bodies and healthcare establishments.

Amongst others, the products below have been tested and proved to cause no damage to DECOCHOC panel:

DETERGENTS	SURFANIOS
	DETERGANIOS
	UNIT PLUS
DETERGENT DISINFECTANTS	DS5001
	DIVOSAN S4
DESCALERS	TASKI CALCACID
PAINT STRIPPERS	TASKI radical
	SUMA D9.7
DEGREASER DISINFECTANTS	DDM
OTHERS	70% surgical alcohol
	Household bleach
	Eosin
	Bétadine
	Ammonia

IT IS ESSENTIAL TO USE SOLVENTS THAT LEAVE NO RESIDUE, EITHER GREASY OR DRY.

In all cases, test the product first on a scrap piece of panel. Reactions will differ depending on the colour of the panels and the solvents used.

SOLVENTS NOT TO BE USED

White spirit

Paint thinners

Petrol

Glass

Glass should be cleaned using a suitable standard glass cleaning agent.

CAUTION

Always follow the manufacturer's instructions carefully when using any cleaning agent or disinfectant. Using a combination of products may cause unwanted chemical reactions which produce harmful gases.

When surfaces have been cleaned with aggressive cleaning agents, they should be rinsed well to dilute the cleaning agent and prevent it from drying on the panel surface.